

# SWEPCO SERVICE INSPECTIONS

In order to serve you better & prevent a dangerous condition with the electric service to your house, here are several easily identifiable items that would need to be corrected before restoring electric power.

1. Address displayed on the front of the building clearly from the street.
  2. No broken or missing light fixtures. (No broken bulbs)
  3. No painted or damage receptacles or switches.
  4. No painted, missing or broken cover plates.
  5. No damage to walls (holes cut too big) around electrical boxes, switches, outlets.
  6. GFCI receptacles must be in bathroom, above kitchen counters, & outdoor receptacles (See example at the bottom)
  7. No extension cords being used for permanent wiring
  8. Working smoke detectors in each bedroom & in hallway connecting to bedrooms. Detectors cannot be painted.
  9. No frayed, broken, or otherwise damage power cords on appliances.
- ✓ Building or dwellings in a condition to be unsafe, as seen by the inspector, shall be refused electric power to the structure, shall be refused electric power to the structure. (Ex. Leaking roof, ceiling falling in, or structural damage to building)

If you have any questions or are ready to schedule an inspection, please feel free to call (903)935-4455 or come by our office at City Hall at 401 S Alamo Blvd

Re-inspection fee of \$50.00 will be added, if requirements are not met.



GFCI Outlets

SWEPCO Inspection
Time: _____
Date: _____
Address: _____