

PUBLIC NOTICE MANDATORY LANGUAGE CODING
Tier 2 violations/ Non-Acute

Mandatory Language for Surface Water Treatment Technique Violation

SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

The CITY OF MARSHALL, PWS ID TX1020002, failed to meet the minimum treatment technique requirements for the month of FEB 2021.

Specifically, our water system had **[using the "Violation List" below, enter the type of violation that occurred]**.

Violation List:

- [Combined filter effluent turbidity readings above 1.0 NTU.]
- More than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.
- Low disinfectant (Free Chlorine) residuals in more than 5% of monthly samples for two consecutive months.
- Low disinfectant (Free Chlorine) residual entering the distribution system for more than four consecutive hours.
- Low disinfectant (Total Chlorine) residuals in more than 5% of the monthly samples for two consecutive months.
- Low disinfectant (Total Chlorine) residual entering the distribution system for more than four consecutive hours.
- **Low Disinfection Contact Time (CT) for more than four consecutive hours.**
- Failure to install filtration by application deadline (GUI).
- Failure to provide *Cryptosporidium* treatment.
- Failure to maintain microbial treatment
- Failure to achieve at least 99% (2-log) removal of *Cryptosporidium*.]

(CORRECTIVE ACTION) You may add other information here if you wish. The added information must appear in one or more separate paragraphs and must be both pertinent and factual. For example, "The SLC WSC has taken the following corrective actions to prevent a recurrence of the violations; [list the actions you have taken]."

*This does not make sense to me. No changes occurred
We were under boil water notice for five days*

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: James McClendon

Area Code + phone number 903 935 4487

Date Posted /Delivered on: 1-8-24

Instructions for preparing the required Public Notice: Recopy the mandatory language above and insert the underlined information in the spaces indicated.

Public Notice delivery timelines: The initial public notice shall be issued as soon as possible, but in no case later than [30 days] after the violation was identified. All notifications require