

PUBLIC NOTICE MANDATORY LANGUAGE CODING
Tier 2 violations/ Non-Acute

Mandatory Language for Surface Water Treatment Technique Violation

SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

The **City of Marshall**, PWS ID TX1020002, failed to meet the minimum treatment technique requirements for the month of **June 2025**. Specifically, our water system had

- More than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.

The City of Marshall has taken the following corrective actions to prevent a recurrence of the violations:

The filter issue has been resolved resulting in normal turbidity readings.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact James McClend at
903-935-4488
<area code + phone number>

Posted /Delivered on: 07/11/2025
<Date Posted>
